

## FACT SHEET 2 LPG

The Hirer shall ensure that all flammable materials and other substances hazardous to health, are controlled in accordance with the Control of Substances Hazardous to Health Regulations 1999 (COSHH).

The Hirer shall ensure that the storage and use of LPG complies with the LPG Association Code of Practice Part 7 – The storage of full and empty LPG cylinders and cartridges, and the Highly Flammable Liquids and LPG Regulations 1972.

All LPG cylinders and flammable material containers, full and empty, shall be stored in the open air, on firm level ground in a well ventilated position, and securely fenced so as to deny access to all except competent and qualified employees or Agents.

Appliances specifically designed for indoor use with cylinders located on or in the appliance, may be used.